

LOG OF BORING

PROJECT: White Point Island Restoration Nueces Bay - Corpus Christi, Texas	PROJECT NO. 1600-0159 BORING NO. B-5 DATE 9/20/2000 ELEV. NA
CLIENT: Shiner Moseley & Associates, Inc. Corpus Christi, Texas	SHEET 1 of 1

FIELD DATA				LABORATORY DATA								DRILLING METHOD (S) :		
SOIL SYMBOL	DEPTH (FT)	SAMPLES	N: BLOWS/FT P: TONS/SQ.FT T: TON/SQ.FT PERCENT RECOVERY/ ROCK QUALITY DESIGNATION	MOISTURE CONTENT	ATTERBERG LIMITS (%)			DRY DENSITY POUNDS/CU.FT	SHEAR STRENGTH (KIPS/SQ.FT)	FAILURE STRAIN (%)	CONFINING PRESSURE (POUNDS/SQ.IN)	MINUS NO. 200 SIEVE (%)	GROUNDWATER INFORMATION:	
					LIQUID LIMIT	PLASTIC LIMIT	PLASTICITY INDEX						Depth of water from surface to mudline at time of drilling was 3.1 ft.	
					LL	PL	PI						DESCRIPTION OF STRATUM	
	5		N=WH										No sample recovery, 0' to 4'.	
			N=WH											
			N=WH	96								68	Clay, very soft, dark gray, with shell fragments and sand pockets.	
			N=1	82										
			N=WH	69										
10													TOTAL DEPTH = 10 FT (Below Mudline)	
	15													
	20													
N - STANDARD PENETROMETER TEST RESISTANCE P - POCKET PENETROMETER RESISTANCE T - POCKET TORVANE SHEAR STRENGTH													REMARKS: PLATE 6	
													FLUGRO SOUTH INC - Gulf Coast Testing	