

LOG OF BORING A-6

SHEET 1 of 1



Rock Engineering & Testing Laboratory
6817 Leopard Street
Corpus Christi, TX 78409-1703
Telephone: 361-883-4555
Fax: 361-883-4711

CLIENT: LP Galveston, Inc.
PROJECT: Pepper Cove Project
LOCATION: Laguna Drive; Galveston, TX
NUMBER: G115231

DATE(S) DRILLED: 12/8/15 - 12/8/15

DRILLING METHOD(S):
Hollow Stem Auger

GROUNDWATER INFORMATION:
Groundwater was encountered at a depth of 3-feet during drilling.
Wet and Caved at 5-feet upon completion.
24-Hour Delayed Readings: Wet and Caved at 2-feet.

SURFACE ELEVATION: N/A

DESCRIPTION OF STRATUM

POORLY GRADED SAND, brown, moist, very loose.

Same as above.

Same as above, loose.

POORLY GRADED SAND, brown, moist, loose.

SILTY SAND, with clay, gray, moist, very loose.

Same as above.

Same as above.

SILTY SAND, with clay, gray, moist, loose.

Same as above, very loose.

Same as above, loose.

CLAYEY SAND, gray, moist, very soft.

Same as above, with shell.

Same as above, dark brown.

FAT CLAY, dark brown, moist, very soft.

Same as above, with shell.

Same as above.

FAT CLAY, with shell, dark brown, moist, very soft.


Boring was terminated at a depth of 25½-feet.

N - STANDARD PENETRATION TEST RESISTANCE
P - POCKET PENETROMETER RESISTANCE
T - POCKET TORVANE SHEAR STRENGTH

REMARKS:

Boring location and depth were determined by Jones | Carter. Drilling operations were performed by RETL at GPS Coordinates N 29° 8' 1.03" W 95° 3' 29.24".


LOG OF BORING G115231 PEPPER COVE PROJECT.GPJ ROCK ETI.GDT 12/8/16




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

[illegible]

Project: Pepper Cove Project
Location: Laguna Drive; Galveston, TX
Number: G115231





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen ID		Depth	Classification				LL	PL	PI	Cc	Cu
●	A-6	6-15'	POORLY GRADED SAND(SP)							1.11	1.68
Specimen ID		Depth	D100	D60	D30	D10	%Gravel	%Sand	%Silt	%Clay	
●	A-6	6-15'	0.425	0.193	0.157	0.115	0.0	99.9	0.1		

GRAIN SIZE DISTRIBUTION



Rock Engineering & Testing Laboratory
6817 Leopard Street
Corpus Christi, TX 78409-1703
Telephone: 361-883-4555
Fax: 361-883-4711

Project: Pepper Cove Project

Location: Laguna Drive; Galveston, TX

Number: G115231