

# LOG OF BORING GS-3



Rock Engineering & Testing Lab. Inc  
6817 Leopard Street  
Corpus Christi, Texas 78409  
Telephone: 361-883-4555  
Fax: 361-883-4711


CLIENT: Mott MacDonald, LLC  
PROJECT: Children's Beach Shoreline Protection  
LOCATION: South Padre Island, Texas  
NUMBER: G121096  
DATE(S) DRILLED: 2/23/2021

FIELD DATA				LABORATORY DATA							DRILLING METHOD(S):	
SOIL SYMBOL	DEPTH (FT)	SAMPLE NUMBER	SAMPLES	N: BLOWS/FT P: TONS/SQ FT T: TONS/SQ FT Qc: TONS/SQ FT	MOISTURE CONTENT (%)	ATTERBERG LIMITS			DRY DENSITY POUNDS/CU.FT	COMPRESSIVE STRENGTH (TONS/SQ FT)	MINUS NO. 200 SIEVE (%)	Grab Sample
						LL	PL	PI				GROUNDWATER INFORMATION:
												SURFACE ELEVATION: N/A
												DESCRIPTION OF STRATUM
												Approximately 3 feet of water
		GRAB S-1			30	NP	NP	NP			2	<p><b>POORLY GRADED SAND</b>, brown, moist. (SP)</p> <p>Grab Sample was terminated at a depth of 1 foot.</p>

N - STANDARD PENETRATION TEST RESISTANCE  
Qc - STATIC CONE PENETROMETER TEST INDEX  
P - POCKET PENETROMETER RESISTANCE  
Tv - TORVANE SHEAR STRENGTH TEST

REMARKS:  
Drilling operations were performed by RETL at GPS Coordinates  
N° 26.06782 W° 97.16273  
Location: Approximately 50 feet seaward of water's edge.





Engineering & Testing  
Laboratory, Inc.

Rock Engineering & Testing Laboratory  
6817 Leopard Street  
Corpus Christi, TX 78409-1703  
Telephone: 361-883-4555  
Fax: 361-883-4711

KEY TO SOIL CLASSIFICATION AND SYMBOLS

UNIFIED SOIL CLASSIFICATION SYSTEM			TERMS CHARACTERIZING SOIL STRUCTURE		
MAJOR DIVISIONS	SYMBOL	NAME			
COARSE GRAINED SOILS	GRAVEL AND GRAVELLY SOILS	GW	Well Graded Gravels or Gravel-Sand mixtures, little or no fines	SLICKENSIDED - having inclined planes of weakness that are slick and glossy in appearance	
		GP	Poorly Graded Gravels or Gravel-Sand mixtures, little or no fines		FISSURED - containing shrinkage cracks, frequently filled with fine sand or silt; usually more or less vertical
		GM	Silty Gravels, Gravel-Sand-Silt mixtures		
		GC	Clayey Gravels, Gravel-Sand-Clay Mixtures	LAMINATED (VARVED) - composed of thin layers of varying color and texture, usually grading from sand or silt at the bottom to clay at the top	
	SAND AND SANDY SOILS	SW	Well Graded Sands or Gravelly Sands, little or no fines	CRUMBLY - cohesive soils which break into small blocks or crumbs on drying	
		SP	Poorly Graded Sands or Gravelly Sands, little or no fines	CALCAREOUS - containing appreciable quantities of calcium carbonate, generally nodular	
		SM	Silty Sands, Sand-Silt Mixtures		WELL GRADED - having wide range in grain sizes and substantial amounts of all intermediate particle sizes
		SC	Clayey Sands, Sand-Clay mixtures	POORLY GRADED - predominantly of one grain size uniformly graded) or having a range of sizes with some intermediate size missing (gap or skip graded)	
FINE GRAINED SOILS	SILTS AND CLAYS LL < 50	ML	Inorganic Silts and very fine Sands, Rock Flour, Silty or Clayey fine Sands or Clayey Silts	SYMBOLS FOR TEST DATA	
		CL	Inorganic Clays of low to medium plasticity, Gravelly Clays, Sandy Clays, Silty Clays, Lean Clays		
		OL	Organic Silts and Organic Silt-Clays of low plasticity		
	SILTS AND CLAYS LL > 50	MH	Inorganic Silts, Micaceous or Diatomaceous fine Sandy or Silty soils, Elastic Silts		— Groundwater Level (Initial Reading)
		CH	Inorganic Clays of high plasticity, Fat Clays		— Groundwater Level (Final Reading)
		OH	Organic Clays of medium to high plasticity, Organic Silts		— Shelby Tube Sample
HIGHLY ORGANIC SOILS	PT	Peat and other Highly Organic soils	— SPT Samples		
				— Auger Sample	
				— Rock Core	

TERMS DESCRIBING CONSISTENCY OF SOIL

COARSE GRAINED SOILS		FINE GRAINED SOILS		
DESCRIPTIVE TERM	NO. BLOWS/FT. STANDARD PEN. TEST	DESCRIPTIVE TERM	NO. BLOWS/FT. STANDARD PEN. TEST	UNCONFINED COMPRESSION TONS PER SQ. FT.
Very Loose	0 - 4	Very Soft	< 2	< 0.25
Loose	4 - 10	Soft	2 - 4	0.25 - 0.50
Medium	10 - 30	Firm	4 - 8	0.50 - 1.00
Dense	30 - 50	Stiff	8 - 15	1.00 - 2.00
Very Dense	over 50	Very Stiff	15 - 30	2.00 - 4.00
		Hard	over 30	over 4.00

Field Classification for "Consistency" is determined with a 0.25" diameter penetrometer