

SHEET 1 of 1



Rock Engineering and Testing Laboratory, Inc.
4910 Neptune Street
Corpus Christi, Texas 78405
Telephone: (361) 883-4555
Fax: (361) 883-4711

CLIENT: Turner, Collie & Braden, Inc.
PROJECT: Indian Point Shoreline Protection
LOCATION: Portland, Texas
NUMBER: C0200557

DATE(S) DRILLED: 06/24/02 - 06/24/02

DRILLING METHOD(S):
Split Spoon and Russian Sampler

GROUNDWATER INFORMATION:
Depth of Water: 3-4 feet

SURFACE ELEVATION: N/A

DESCRIPTION OF STRATUM

POORLY GRADED SAND, with shell fragments, trace clay,
brown, moist, medium.

Same as above, loose.

Same as above, with clay.

POORLY GRADED SAND, trace shell, very loose. (SP) Soil samples were not obtained below a depth of 4-feet.

Static cone penetrometer tests were terminated at a depth of 10-feet.

REMARKS:

Boring location was determined by Turner, Coffe & Braden, Inc. Boring was performed by RETL at N 27.8510498 deg W 97.3508125 deg

N - STANDARD PENETRATION TEST RESISTANCE
P - POCKET PENETROMETER RESISTANCE
T - POCKET TORVANE SHEAR STRENGTH



